



PRIMARY HEALTH CENTRE-SEVNI

બેટી બચાવો બેટી પઢાવો



NR.TALAV FALIYU, SEVANI, TA.KAMREJ DIST. SURAT – 394320

MO. 9727709540

E-MAIL: mosevani@yahoo.in

PH. 02621 299521

Annexure – C

Proforma for Safe Drinking Water and Sanitary Condition Certificate

No:

Date: 26/12/2023

It is certified that an inspection team headed by Dr. Jitesh S. Rana from Sevani Primary Health Center, Surat inspected the **MATRIX GLOBAL SCHOOL**, Umragam, Velanja-Hazira Road, Opp. Bapasitaram Petroleum, Olpad, Surat on 24th of December 2023, checked the water test report submitted by the school and found that the School has portable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the State Govt.

The above is valid for a period of One Year from 26th of December 2023 to 26th of December 2024.

Signature with seal:

Name:

J. S. Rana
Dr. Jitesh S. Rana

Designation:

Officer
Primary Health Center
SEVANI, Tal.Kamrej



PRIMARY HEALTH CENTRE-SEVNI



બેટી બચાવો બેટી પઢાવો

NR.TALAV FALIYU, SEVANI, TA.KAMREJ DIST. SURAT – 394320

MO. 9727709540

E-MAIL: mosevani@yahoo.in

PH. 02621 299521

Water Sample Test Report

Name and Address of School: Matrix Global School, Umragam, Velanja-Hazira Road,
Opp. Bapasitaram Petroleum, Olpad, Surat

Type of Sample : Water

Laboratory : GWSSB District Laboratory, Surat

Date of Sample : 19/12/2023

Date of Analysis : 20/12/2023

Source of Sample : Filtered Water

Sr.No.	Quality Characteristic Test	Result	Prescribed Standards a per IS 10500:2012
1.	Turbidity	Clear	Max. 1 NTU.
2.	Taste	Agreeable	Agreeable
3.	Free Residual Chlorine	Absent	Max. 0.2mg/lit.
4.	Odour	Agreeable	Agreeable
5.	PH Value	7.3	6.5 to 8.5
6.	Ammonia (as Total Ammonia-N)	Absent	Max. 0.5mg/lit.
7.	Nitrate (as NO ₃)	Absent	Max. 45mg/lit
8.	Chlorides (as Cl)	07.0	Max. 250mg/lit.
9.	Total Alkalinity (as Calcium Carbonate)	15.0	Max. 200mg/lit.
10.	Total Hardness (as CaCO ₃)	10.0	Max. 200mg/lit.
11.	Total Dissolved Solids	35.0	Max. 500mg/lit.

Opinion:- The Sample is FIT for drinking Purpose, With Respect to the Test Performed above.


MEDICAL OFFICER
Primary Health Center
Sevni, Tal. Kamrej